



## Proposed Code Change

State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

### FOR OFFICE USE ONLY

Received 10/2/09

Code 52.4.4.5-09

#### INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 INDIANA RESIDENTIAL CODE		Edition FIRST EDITION
Section number and title M1411.3.1 CONDENSATE DISPOSAL		Page 1 OF 1
Proponent JOHN R. WEESNER	Title CONSULTANT	
Address P.O. BOX 876 FRANKFORT, IN 46041		Phone 765-242-5503
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input checked="" type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<p>M1411.3.1 IN ADDITION TO THE REQUIREMENTS OF SECTION M1411.3, A SECONDARY DRAIN OR AUXILIARY DRAIN PAN SHALL BE REQUIRED FOR EACH COOLING OR EVAPORATOR COIL <del>WHERE DAMAGE TO ANY BUILDING COMPONENTS WILL OCCUR AS A RESULT OF OVERFLOW FROM THE EQUIPMENT DRAIN PAN OR STOPPAGE IN THE CONDENSATE DRAIN PIPING.</del> <b><u>INSTALLED OVER A FINISHED CEILING.</u></b> SUCH PIPING SHALL MAINTAIN A MINIMUM HORIZONTAL SLOPE IN THE DIRECTION OF DISCHARGE OF NOT LESS THAN 1/8 UNIT VERTICAL IN 12 UNITS HORIZONTAL (1 PERCENT SLOPE). DRAIN PIPING SHALL BE A MINIMUM OF 3/4 INCH (19mm) NOMINAL PIPE SIZE. ONE OF THE FOLLOWING METHODS SHALL BE USED:</p> <p>ITEMS 1-4 REMAIN UNCHANGED.</p> <p><b>EXCEPTION:</b> <u>WHEN INSTALLED ON A WATER-RESISTANT FLOOR WITH A FLOOR DRAIN IN THE SAME ROOM OR SPACE.</u></p>		
REASON AND FISCAL IMPACT		
<p>THIS PROPOSAL IS IN THE CURRENT CODE AS WRITTEN.</p> <p>FISCAL IMPACT; NO INCREASE TO THE COST OF CONSTRUCTION. IS IN CURRENT CODE.</p>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		